

**XR02CX / XR03CX - FOR REFRIGIERATOR
(115V/60Hz)**

Parameter	Function	Range	Manufacturer Setting	Remark
Hy	Differential	1~45°F	7°F	
LS	Minimum Set Point	-67°F ~SET	33°F	
US	Maximum Set Point	SET~99°F	43°F	
ot	First probe calibration	-17~17°F	0	Adjusted by factory
od	Outputs activation delay at start up	0 ~99 minutes	2	
CF	Measurement units	°C/ °F	°F	
id	Interval between defrost cycles	0~ 99 hours	6	
Md	Maximum length for defrost	0~99 minutes	20	
F1			oy	
F2			oy	



1. Hold "set" & "▼" Button by two fingers at the same time, "HY" will show up and leave your two finger now. Rehold "set" & "▼" Button until "L2" shows up. Now you can choose the parameter through "▼""▲"
2. Please refer the left introduction about the parameters
3. Save Parameters: After finish the setting, please hold the "Set" & "▲" buttons at the same time, thus the setting will be saved.